



This report is intended to provide you with important information about your drinking water and the efforts made by the City Of Peru water system to provide safe drinking water.

For more information regarding this report, or to request a hard copy, contact:

HARLEY ALAN SLATER
402-274-4981

If you would like to observe the decision-making processes that affect drinking water quality, please attend the regularly scheduled meeting of the Village Board/City Council. If you would like to participate in the process, please contact the Village/City Clerk to arrange to be placed on the agenda of the meeting of the Village Board/City Council.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The Nebraska Department of Environment and Energy (NDEE) has completed the Source Water Assessment. Included in the assessment are a Wellhead Protection Area map, potential contaminant source inventory, and source water protection information. To view the Source Water Assessment or for more information please contact the person named above on the report or the NDEE at 402-471-3376 or go to <http://dee.ne.gov>

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up

substances resulting from the presence of animals or from human activity.

The source of water used by City Of Peru is ground water

- * Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- * Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

- * Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- * Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- * Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. All Community water systems are responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791), at <http://www.epa.gov/safewater/lead> or at the NDEE Drinking Water Division (402-471-1009).

The City Of Peru is required to test for the following contaminants:

Arsenic, Asbestos, Barium, Beryllium, Cadmium, Chromium, Copper, Cyanide, Fluoride, Lead, Mercury, Nickel, Nitrate, Nitrite, Selenium, Sodium, Thallium, Alachlor, Atrazine, Benzof(a)pyrene, Carbofuran, Chlordane, Dieldrin, Di(2-ethylhexyl)-phthalate, Diquat, 2,4-Dichlorodimethoxyphenol, Dinoseb, Di(2-ethylhexyl)-phthalate, Disinfectant Byproducts, Endrin, Hexachlorobiphenyls, Heptachlor Epoxide, Heptachlorobenzene, Hexachlorocyclopentadiene, Heptachlor epoxide, Heptachlorobenzene, Hexachlorocyclopentadiene, Lindane, Methoxychlor, Oramyl (Vydate), Pentachlorophenol, Picloram, Polychlorinated biphenyls, Simazine, Toxaphene, Dioxin, Silvex, Benzene Carbon Tetrachloride, o-Dichloro- benzene, Para-Dichlorobenzene, 1,2-

Dichloroethane, 1,1-Dichloroethylene, Cis-1,2-, Dichloroethylene, Trans-1,2-
Dichloroethylene, Dichloromethane, 1,2-Dichloropropane, Ethylbenzene,
Monochlorobenzene, 1,2,4-Trichloro- benzene, 1,1,1-Trichloroethane,
1,1,2-Trichloroethane, Trichloroethylene, Vinyl Chloride, Styrene,
Tetrachloroethylene, Toluene, Xylenes (total), Goss Alpha (minus
Uranium & Radium 226), Radium 226 plus Radium 228, Sulfate,
Chloroform, Bromodichloromethane, Chlorodibromomethane, Bromoform,
Chlorobenzene, m-Dichlorobenzene, 1,1-Dichloropropene, 1,1-
Dichloroethane, 1,1,2,2-Tetrachloroethane, 1,2-Dichloropropane,
Dichloromethane, Bromomethane, 1,2,3-Trichloropropane, 1,1,1,2-Tetra-
chloroethane, Chloroethane, 2,2-Dichloropropane, o-Chlorotoluene, p-
Chlorotoluene, Bromobenzene, 1,3-Dichloropropane, Aldrin, Butachlor,
Carbaryl, Dicamba, Dieldrin, 3-Hydroxy-carbopuran, Methomyl, Metolachlor,
Methidathion, Propachlor.

The EPA and State Drinking Water Program establish the safe drinking water regulations that limit the amount of contaminants allowed in drinking water. The table shows the concentrations of detected substances in water. The table states if a substance was detected or not compared to the regulatory limits. Substances not detected are not included in the table. The state requires monitoring of certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of this data may be older than one year.

MCL (Maximum Contaminant Level) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

AL (Action Level) – The concentration of a contaminant which, if exceeded triggers treatment or other requirements which a water system must follow.

MRDL (Maximum Residual Disinfectant Level) – The highest level of a disinfectant allowed in drinking water.

N/A – Not applicable

ND – Not detectable.
ppm (parts per million) – One ppm corresponds to 1 gallon of concentrate in 1 million gallons of water.

mg/L (milligrams per liter) – Equivalent to ppm.
ppb (parts per billion) – One ppb corresponds to 1 gallon of concentrate in 1 billion gallons of water.
ug/L (micrograms per liter) – Equivalent to ppb.
pCi/L (Picrocuries per liter) – Radioactivity concentration unit
RAA (Running Annual Average) – An ongoing annual average
calculation of data from the most recent four quarters.

LRAA (Long-term Running Annual Average) – An ongoing annual sampling calculation of data from the most recent four quarters at each sampling location.

90th Percentile – Represents the highest value found out of 90% of the samples taken in a representative group. If the 90th percentile is greater than the action level, it will trigger a treatment or other requirements that a water system must follow.

TT (Treatment Technique) – A required process intended to reduce the level of a contaminant in drinking water.

TT (Treatment Technique) – A required process intended to reduce the level of a contaminant in drinking water.

TEST RESULTS

Date Printed: 3/8/2023

NE3112705

Microbiological		Highest No. of Positive Samples		MCL		MCLG		Likely Source of Contamination		Violations Present	
COLIFORM (TCR)		In the month of April, 1 sample(s) were positive		Treatment Technique Trigger		0		Naturally present in the environment		Yes	
Lead and Copper	Monitoring Period	90 th Percentile	Range	Unit	AL	Sites Over AL	Likely Source of Contamination				
COPPER, FREE	2018 - 2020	0.447	0.0722 - 0.662	ppm	1.3	0	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.				
							Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.				
LEAD	2018 - 2020	4.72	0.783 - 4.87	ppb	15	0					
Regulated Contaminants		Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination			
BARIUM		2/1/2021	0.238	0.238	ppm	2	2	Discharge from drilling wastes; Discharge from metal refineries; Erosion of natural deposits.			
CHROMIUM		2/1/2021	0.544	0.544	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits.			
FLUORIDE		2/1/2021	0.339	0.339	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; Fertilizer discharge.			
NITRATE-NITRITE		8/15/2022	1.18	1.18	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits			
SELENIUM		2/1/2021	6.93	6.93	ppb	50	50	Erosion of natural deposits			
Disinfection Byproducts		Monitoring Period		Highest RAA	Range	Unit	MCL	MCLG	Likely Source of Contamination		
TOTAL HALOACETIC ACIDS (HAA5)		1/1/2022 - 12/31/2022		9.145	7.29 - 11	ppb	60	0	By-product of drinking water disinfection.		
THHM		7/1/2021 - 6/30/2022		28.95	25.7 - 32.2	ppb	80	0	By-product of drinking water disinfection.		
Radiological Contaminants		Collection Date		Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination		
GROSS ALPHA, INCL. RADON & U		4/18/2018		7.94	7.94	pCi/L	15	0	Erosion of natural deposits		
Unregulated Water Quality Data		Collection Date		Highest Value		Range	Unit	Secondary MCL			
SULFATE		1/22/2019		58		58	mg/L	250			
During the 2022 calendar year, we had the below noted violation(s) of drinking water regulations.											
Violation Type		Category		Analyte		Compliance Period					

There are no additional required health effects notices.

There are no additional required health effects violation notices.